

A vertical graphic on the left side of the page depicts a water splash. It features a long, thin stream of water falling from the top, followed by a larger, more turbulent splash with numerous bubbles and droplets. The background of this graphic is a gradient of light blue to white. A solid blue vertical bar runs parallel to the right edge of this graphic.

Our Drinking Water is SAFE!

**City of Carlin
2015 Annual Consumer Confidence Report**

We are pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is one well and one spring located approximately 6 miles outside of town.

This report shows our water quality and what it means.

CONTACT INFORMATION:

If you have any questions about this report or concerning your water utility, please contact Carlos Esparza at 775-754-6515. We want our valued customers to be informed about their water utility.

City of Carlin routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2015. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

DEFINITIONS:

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions. (Only systems with a variance or exemption are REQUIRED to include this definition. In

addition, it is REQUIRED to provide an explanation of the reasons for the variance or exemption, date issued, status or remediation.)

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - (mandatory language) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - (mandatory language) The 'Maximum Allowed' (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - (mandatory language) The 'Goal' (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - (mandatory language) The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - (mandatory language) The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Contaminants							
Contaminant	Level Detected	Range of Detection	Unit of Measure	MCL	MCLG	Violation	Likely Source
Disinfection Byproducts							
Haloacetic Acids (HAA5) Collection Dates: 09/12/2012- 09/22/2015	4	4.0-4.0	ug/L	60		N	By-product of drinking water chlorination.
Total Trihalomethanes (TTHMs) Collection Dates: 09/12/2012- 09/22/2015	14	14-14	ug/L	80	n/a	N	By-product of drinking water chlorination
Inorganic Chemicals							
Arsenic Collection Dates: 05/16/2013- 05/16/2013	7	7-7	ppb	10	n/a	N	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium Collection Date: 05/05/2010	0.16	0.16-0.16	mg/L	2	2	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Collection Date: 05/05/2010	1	1-1	ppb	100	100	N	Discharge from steel and pulp mills; erosion of natural deposits
Copper Collection Date: 2007	0.39	0.39	Mg/l	1.3	1.3	N	Corrosion of household plumbing systems, erosion of natural deposits.
Fluoride Collection Dates: 05/16/2013- 05/16/2013	0.6	0.6-0.6	mg/L	4	4	N	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Collection Date: 2007	3	3	Ppb	15	0	N	Corrosion of household plumbing systems, erosion of natural deposits.
NO3 (Nitrate) Collection Dates: 06/09/2015- 06/09/2015	0.75	0.54-0.95	mg/L	10	10	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Radionuclides							
Alpha Particles Collection Dates: 06/09/2015	6.76	4.12-9.40	pCi/L	15	0	N	Decay of natural and man-made deposits
Beta Particles and Photon Emitters Collection Date: 06/9/2015	11.2	7.42-11.2	pCi/L	50	0	N	Decay of natural and man-made deposits.
Radium 226 Collection Date: 06/09/2015	0.501	0.230-0.501	pCi/L	5	0	N	Erosion of natural deposits
Radium 228 Collection Date: 06/09/2015	1.66	0.707-1.66	pCi/L	5	0	N	Erosion of natural deposits
Uranium Collection Dates: 06/06/2012	6	5-6	ug/L	30	0	N	Erosion of natural deposits

HEALTH EFFECTS:

Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Este informe contiene informacion muy importante sobre su agua de beber. Traduzcalo o hable con alguien que lo entienda bien.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have questions. We at the City of Carlin work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

EXPLANATIONS:

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. The MCLs are set such that out of every 10,000 or 1,000,000 people (depends upon how the MCL was developed) drinking 2 liters of water every day for a lifetime, only 1 of those people may experience the described health effect.